

### Bid Document

<b>Bid Details</b>	
<b>Bid End Date/Time</b>	23-05-2022 18:00:00
<b>Bid Opening Date/Time</b>	23-05-2022 18:30:00
<b>Bid Life Cycle (From Publish Date)</b>	90 (Days)
<b>Bid Offer Validity (From End Date)</b>	60 (Days)
<b>Ministry/State Name</b>	Ministry Of Finance
<b>Department Name</b>	Department Of Economic Affairs
<b>Organisation Name</b>	Security Printing And Minting Corporation Of India Limited (spmci)
<b>Office Name</b>	Janpath
<b>Total Quantity</b>	504
<b>Item Category</b>	Supply of power cable 240 Sq. mm. x 3 and ½ core XLPE insulated, unarmoured multistrand flexible cop (Q3) , Laying, installation, commissioning and testing of power cable 240 Sq. mm. x 3 and ½ core copper con (Q3) , Supply of the Copper Earthing conductor (Q3) , Installation laying and testing of the Copper Earthing conductor double run (Q3) , Supply of PVC insulated Unarmoured Copper Flexible power cable 150 Sq. mm. x4 core (Q3) , Laying, installation, commissioning and testing of power cable 150 Sq. mm. x 4core copper conductor (Q3) , Supply of PVC insulated Unarmoured Copper Flexible multi-stranded power cable 25 Sq. mm. x4 core (Q3) , Laying, installation, commissioning and testing of power cable 25 Sq. mm. x 4core copper conductors, (Q3)
<b>Years of Past Experience required</b>	1 Year (s)
<b>MSE Exemption for Years Of Experience and Turnover</b>	Yes
<b>Startup Exemption for Years Of Experience and Turnover</b>	Yes
<b>Document required from seller</b>	Experience Criteria,Past Performance,Bidder Turnover,Certificate (Requested in ATC) *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
<b>Past Performance</b>	40 %
<b>Bid to RA enabled</b>	No
<b>Primary product category</b>	Laying, installation, commissioning and testing of power cable 25 Sq. mm. x 4core copper conductors,
<b>Time allowed for Technical Clarifications during technical evaluation</b>	7 Days

**Bid Details****Evaluation Method**

Total value wise evaluation

**EMD Detail**

Advisory Bank	Indusind bank
EMD Percentage(%)	2.00
EMD Amount	60584

**ePBG Detail**

Advisory Bank	Indusind bank
ePBG Percentage(%)	3.00
Duration of ePBG required (Months).	17

(a). EMD EXEMPTION: The bidder seeking EMD exemption, must submit the valid supporting document for the relevant category as per GeM GTC with the bid. Under MSE category, only manufacturers for goods and Service Providers for Services are eligible for exemption from EMD. Traders are excluded from the purview of this Policy.

(b). EMD & Performance security should be in favour of Beneficiary, wherever it is applicable.

**Beneficiary:**

CHIEF GENERAL MANAGER  
CURRENCY NOTE PRESS, JAIL ROAD NASHIK ROAD, NASHIK-422101  
(Currency Note Press, A Unit Of Spmcil)

**Splitting**

Bid splitting not applied.

**MII Purchase Preference**

MII Purchase Preference	Yes
-------------------------	-----

**MSE Purchase Preference**

MSE Purchase Preference	Yes
-------------------------	-----

1. If the bidder is a Micro or Small Enterprise as per latest definitions under MSME rules, the bidder shall be exempted from the requirement of "Bidder Turnover" criteria and "Experience Criteria". If the bidder is OEM of the offered products, it would also be exempted from the "OEM Average Turnover" criteria. In case any bidder is seeking exemption from Turnover / Experience Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer.
2. If the bidder is a Startup, the bidder shall be exempted from the requirement of "Bidder Turnover" criteria and "Experience Criteria". If the bidder is OEM of the offered products, it would also be exempted from the "OEM Average Turnover" criteria. In case any bidder is seeking exemption from Turnover / Experience Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer.
3. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM {themselves or

through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU / Public Listed Company for number of Financial years as indicated above in the bid document before the bid opening date. Copies of relevant contracts to be submitted along with bid in support of having supplied some quantity during each of the Financial year. In case of bunch bids, the category of primary product having highest value should meet this criterion.

4. Preference to Make In India products (For bids < 200 Crore):Preference shall be given to Class 1 local supplier as defined in public procurement (Preference to Make in India), Order 2017 as amended from time to time and its subsequent Orders/Notifications issued by concerned Nodal Ministry for specific Goods/Products. The minimum local content to qualify as a Class 1 local supplier is denoted in the bid document. If the bidder wants to avail the Purchase preference, the bidder must upload a certificate from the OEM regarding the percentage of the local content and the details of locations at which the local value addition is made along with their bid, failing which no purchase preference shall be granted. In case the bid value is more than Rs 10 Crore, the declaration relating to percentage of local content shall be certified by the statutory auditor or cost auditor, if the OEM is a company and by a practicing cost accountant or a chartered accountant for OEMs other than companies as per the Public Procurement (preference to Make-in -India) order 2017 dated 04.06.2020. Only Class-I and Class-II Local suppliers as per MII order dated 4.6.2020 will be eligible to bid. Non - Local suppliers as per MII order dated 04.06.2020 are not eligible to participate. However, eligible micro and small enterprises will be allowed to participate .In case Buyer has selected Purchase preference to Micro and Small Enterprises clause in the bid, the same will get precedence over this clause.

5. Purchase preference to Micro and Small Enterprises (MSEs): Purchase preference will be given to MSEs as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail the Purchase preference, the bidder must be the manufacturer of the offered product in case of bid for supply of goods. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service. If L-1 is not an MSE and MSE Seller (s) has/have quoted price within L-1+ 15% (Selected by Buyer)of margin of purchase preference /price band defined in relevant policy, such Seller shall be given opportunity to match L-1 price and contract will be awarded for 25%(selected by Buyer) percentage of total QUANTITY.

6. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.

7. Past Performance: The Bidder or its OEM {themselves or through re-seller(s)} should have supplied same or similar Category Products for 40% of bid quantity, in at least one of the last three Financial years before the bid opening date to any Central / State Govt Organization / PSU / Public Listed Company. Copies of relevant contracts (proving supply of cumulative order quantity in any one financial year) to be submitted along with bid in support of quantity supplied in the relevant Financial year. In case of bunch bids, the category related to primary product having highest bid value should meet this criterion.

## **Supply Of Power Cable 240 Sq. Mm. X 3 And½ Core XLPE Insulated, Unarmoured Multistrand Flexible Cop ( 100 meter )**

**(Minimum 50% and N/A Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)**

Brand Type	Unbranded
------------	-----------

### **Technical Specifications**

Buyer Specification Document	<a href="#">Download</a>
------------------------------	--------------------------

**Consignees/Reporting Officer and Quantity**

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Ashok Ramdas Varma	422101,Currency Note Press, Nashik Road Nashik , Maharashtra	100	90

**Laying, Installation, Commissioning And Testing Of Power Cable 240 Sq. Mm. X 3 And 1/2 Core Copper Con ( 1 set )**

(Minimum 50% and N/A Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Brand Type	Unbranded
------------	-----------

**Technical Specifications**

Buyer Specification Document	<a href="#">Download</a>
------------------------------	--------------------------

**Consignees/Reporting Officer and Quantity**

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Ashok Ramdas Varma	422101,Currency Note Press, Nashik Road Nashik , Maharashtra	1	90

**Supply Of The Copper Earthing Conductor ( 200 meter )**

(Minimum 50% and N/A Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Brand Type	Unbranded
------------	-----------

**Technical Specifications**

Buyer Specification Document	<a href="#">Download</a>
------------------------------	--------------------------

**Consignees/Reporting Officer and Quantity**

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Ashok Ramdas Varma	422101,Currency Note Press, Nashik Road Nashik , Maharashtra	200	90

### Installation Laying And Testing Of The Copper Earthing Conductor Double Run ( 1 set )

(Minimum 50% and N/A Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Brand Type	Unbranded
------------	-----------

#### Technical Specifications

Buyer Specification Document	<a href="#">Download</a>
------------------------------	--------------------------

#### Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Ashok Ramdas Varma	422101,Currency Note Press, Nashik Road Nashik , Maharashtra	1	90

### Supply Of PVC Insulated Unarmoured Copper Flexible Power Cable 150 Sq. Mm. X4 Core ( 100 meter )

(Minimum 50% and N/A Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Brand Type	Unbranded
------------	-----------

#### Technical Specifications

Buyer Specification Document	<a href="#">Download</a>
------------------------------	--------------------------

#### Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
-------	-----------------------------	---------	----------	---------------

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Ashok Ramdas Varma	422101,Currency Note Press, Nashik Road Nashik , Maharashtra	100	90

**Laying, Installation, Commissioning And Testing Of Power Cable 150 Sq. Mm. X 4core Copper Conductor ( 1 set )**

**(Minimum 50% and N/A Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)**

Brand Type	Unbranded
------------	-----------

**Technical Specifications**

Buyer Specification Document	<a href="#">Download</a>
------------------------------	--------------------------

**Consignees/Reporting Officer and Quantity**

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Ashok Ramdas Varma	422101,Currency Note Press, Nashik Road Nashik , Maharashtra	1	90

**Supply Of PVC Insulated Unarmoured Copper Flexible Multi-stranded Power Cable 25 Sq. Mm. X4 Core ( 100 meter )**

**(Minimum 50% and N/A Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)**

Brand Type	Unbranded
------------	-----------

**Technical Specifications**

Buyer Specification Document	<a href="#">Download</a>
------------------------------	--------------------------

**Consignees/Reporting Officer and Quantity**

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Ashok Ramdas Varma	422101,Currency Note Press, Nashik Road Nashik , Maharashtra	100	90

### Laying, Installation, Commissioning And Testing Of Power Cable 25 Sq. Mm. X 4core Copper Conductors, ( 1 set )

(Minimum 50% and N/A Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Brand Type	Unbranded
------------	-----------

#### Technical Specifications

Buyer Specification Document	<a href="#">Download</a>
------------------------------	--------------------------

#### Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Ashok Ramdas Varma	422101,Currency Note Press, Nashik Road Nashik , Maharashtra	1	90

### Buyer Added Bid Specific Terms and Conditions

#### 1. Buyer Added Bid Specific ATC

Buyer Added text based ATC clauses

#### **A) TECHNICAL SPECIFICATIONS:**

##### **ITEM 1 :**

Supply of power cable 240 Sq. mm. x 3 and ½ core XLPE insulated, unarmoured multistrand flexible copper conductor cable.

QTY: 100 Mtr

1.1 KV 240 Sq.mm X 3.5core copper flexible multi-stranded power cable.

XLPE (Cross linked polyethylene insulated) inner sheathed, Conductor: Copper multi-stranded, flexible, Copper as per Class-2 of IS: 8130

Minimum inner sheath thickness: 0.6mm or more, as per IS: 5831

Nominal insulation thickness: 1.2 mm or more

Voltage grade: 1.1 KV, Size: 240Sq.mm, core: 3.5

Nominal system voltage: 440 +/- 10%

S/ckt. Current rating for 1 sec duration: above 33KA

Nominal system frequency: 50Hz +/- 3%

Maximum conductor temperature: 90 Degree C

Maximum conductor temperature: in short circuit: 250 Degree C

Conductor Type Stranded, insulating material: PVC

Confirming to all latest applicable IS standards, IS: 7098(Part 1) / 1988

Core identification strips: Red, Yellow, and Blue and Black.

The firm should submit cable test certificate from the manufacturer.

Make: Polycab/ Havells, /CCI/Lapp

## **ITEM 2:**

Laying ,installation ,commissioning and testing of power cable 240 Sq. mm. x 3 and ½ core copper conductor , XLPE Insulated, unarmored power cable from New Power D.B SuNu-II to proposed Komori machine power transformer in SUNU-II CNP-I .

Qty: 100 Mtr.

a)The firm shall carryout the cable laying , installation commissioning and testing work of above supplied power cable from New Power DB to mains of Komori machine power transformer in SUNU-II CNP-I .

b)The firm shall supply all required Cable Gland, Lugs, Clamp, required for laying, termination and installation work of the power cable at Power Distribution Panel and Main Switches.

c) The firm shall route the cable on existing cable trench and wherever the cable trench are not available the firm shall provide the GI trays of required size and thickness.

d) The firm shall fix and route the cable from the route specified by CNP Authority. The cable shall be fixed with Clamps strong enough to hold the cable at its position. All clamps should be of heavy duty, G.I. material.

e) If required the Firm should provide the cable marker throughout the route of cable at interval minimum of 3 mtr distance to trace the cable.

f) The copper lugs should be used for connection to copper bus-bar etc. All



fasteners used should be rustproof.

g) The accessories like Lugs, cable gland etc should be reputed make like Dowels, Jenison, Etc.

Testing: a) The firm shall carry out the megger test for the cable installation before charging the power cable and submit the report.

b) The firm shall charge the cable after permission of CNP authority in presence of CNP engineer.

### **ITEM 3 :**

Supply of the Copper Earthing conductor for the Komori machine to Main switch cabinet and auxiliary installations.

Supply of Copper Earthing Conductor

Grade of the conductor: Electrolytic

Conductor Purity: 99.9% pure copper conductor

Size of the conductor: 25 mm x 5 mm

Standard Quality as per IS1897(2008)

Qty: 200 Mtr

Make : Any standard

### **ITEM 4:**

Installation laying and testing of the Copper Earthing conductor double run for the proposed Komori machine, SuNu 3 and UV dryer, air compressor and auxiliary installations.

a)The firm shall route and lay the double run copper earthing Conductor (size: 25 mm x 5mm) from power panels to the proposed Komori machine ,SuNu 3 and UV dryer ,air compressorand auxiliary installations fixed with the copper / brass nut bolts.

Note: The firm shall arrange to provide the earthing for the machine and UV dryer unit with cable of single core, PVC insulated flexible multi stranded 50sq.mm size with necessary lugs and nut bolt from the nearest copper earthing termination carried by the firm.

b) The earthing conductor shall be fixed with rectangular clamp or proper fixing arrangement; it should not be loose along the route.

c) The earthing conductor should be properly terminated to the Machines Panel fixed with the copper / brass nut bolts.

d) Each and every joint during the laying of the copper conductor shall be overlapped more than 6" and joint shall be fixed with the copper / brass nut and bolts (minimum 3 nos of nut and bolts with proper washer).

e) If required the bare conductor should be cover with heat shrinkable insulated sleeve.

f) The proper insulator shall be provided, if any crossover with other earthing / metal during the laying of conductor to avoid any interference due to other earthing conductor.

**ITEM 5:**

Supply of PVC insulated Unarmoured Copper Flexible power cable 150 Sq. mm.x4 core

Qty: 100meters

PVC Insulated, inner sheathed, unarmoured Power Cable

Conductor: Copper multi-strand, Flexible

Copper as per Class-2 of IS: 8130

Insulation thickness: 1.8 mm or above

Insulation material: PVC Type-A OR HR PVC Type-C as per IS: 5831

Voltage Grade: 1.1 KV

Size: 150 Sq.mm, Core: 4

Confirming to all latest applicable IS standards, IS: 7098(Part 1) / 1988, as per class 2 of IS: 8130 (Part-I)/1984,

Nominal System Voltage: 440 V +/- 10%,

Nominal System Frequency: 50 Hz +/-3%

Max. Conductor temperature: 90o C, Maximum Conductor Temperature in short circuit: 250 oC Conductor type: Stranded, Insulating Material: PVC

Core Identification Strips: Red, Yellow, Blue, and Black (for Neutral)

Inner Sheath: PVC Type ST-1 as per IS: 5831; Options: PVC Type ST-2/FR Type/FRLS Type

Outer Sheath: PVC Type ST-1 as per IS: 5831; Options: PVC Type ST-2/FR Type/FRLS Type

Colour of Outer Sheath: Black or any other Colour as per requirement

The firm should submit cable test certificate from the manufacturer.

Make: Polycab / BCH /CCI /Havells/Lapp

## **ITEM 6 :**

Laying ,installation ,commissioning and testing of power cable 150 Sq. mm. x 4core copper conductor , PVC Insulated, unarmored power cable from New Power D.B SuNu-II to proposed Komori machine UV drying power unit in SUNU-II CNP-I . Qty: 100 Mtr

a)The firm shall carryout the cable laying , installation commissioning and testing work of above supplied power cable from New Power DB to mains of Komori machine UV drying power unit in SUNU-II CNP-I

b)The firm shall supply all required Cable Gland, Lugs, Clamp , metallic ladders, tools and tackles whichever is required for laying, termination and installation work of the power cable at Power Distribution Panel and Main Switches .

c) The firm shall route the cable on existing cable trench and wherever the cable trench are not available the firm shall provide the GI trays of required size and thickness.

d) The firm shall fix and route the cable from the route specified by CNP's Authority. The cable shall be fixed with Clamps strong enough to hold the cable at its position. All clamps should be of heavy duty, G.I. material.

e) If required the Firm should provide the cable marker throughout the route of cable at interval minimum of 3 mtr distance to trace the cable.

f) The copper lugs should be used for connection to copper bus-bar etc. All fasteners used should be rustproof.

g) The accessories like Lugs, cable gland etc should be reputed make like Dowels, Jenison, Etc.

Testing: a) The firm shall carry out the megger test for the cable installation before charging the power cable and submit the report.

b) The firm shall charge the cable after permission of CNP authority in presence of CNP engineer.

## **ITEM 7:**

Supply of PVC insulated Unarmoured Copper Flexible multi-stranded power cable 25 Sq. mm.x4 core

Qty: 100meters

1.1 KV 25 Sq.mm X 4 core copper flexible multi-stranded power cable.

PVC insulated, inner sheathed, Un-armoured flexible multi-stranded power cable

Conductor: Copper multi-stranded, flexible

Voltage grade: 1.1 KV, Size: 25Sq.mm, core: 4

Confirming to all latest applicable IS standards, IS: 694:1990/IS8130:2013

Nominal system voltage: 440 +/- 10%

Nominal system frequency: 50Hz +/- 3%

Maximum conductor temperature: 90 Degree C

Maximum conductor temperature: in short circuit: 250 Degree C

Conductor Type Stranded, insulating material: PVC

Core Identification Strips: Red, Yellow, Blue, and Black (for Neutral)

The firm should submit cable test certificate from the manufacturer.

Make: Polycab / BCH /CCI /Havells/Lapp

**ITEM 8:**

Laying, installation, commissioning and testing of power cable 25 Sq. mm. x 4core copper conductors, PVC Insulated, unarmored power cable from New Power D.B SuNu-II

a) To proposed Komori machine Air compressor switch cabinet in SUNU-II CNP-I.

b) To SuNu -03 machine switch cabinet.

Qty: 100 Mtr

The firm shall carryout the cable laying, installation commissioning and testing work of above supplied power cable from New Power DB

a) To proposed Komori machine Air compressor switch cabinet in SUNU-II CNP-I.

b) To SuNu -03 machine switch cabinet.

The firm shall supply all required Cable Gland, Lugs, Clamp required for laying, termination and installation work of the power cable at Power Distribution Panel and Main Switches.

c) The firm shall route the cable on existing cable trench and wherever the cable trench are not available the firm shall provide the GI trays of required size and thickness.

d) The firm shall fix and route the cable from the route specified by CNP's Authority. The cable shall be fixed with Clamps strong enough to hold the cable at its position. All clamps should be of heavy duty, G.I. material.

e) If required the Firm should provide the cable marker throughout the route of cable at interval minimum of 3 mtr distance to trace the cable.

f) The copper lugs should be used for connection to copper bus-bar etc. All fasteners used should be rustproof.

g) The accessories like Lugs, cable gland etc should be reputed make like Dowels, Jenison, Etc.

Testing: a) The firm shall carry out the megger test for the cable installation before charging the power cable and submit the report.

b) The firm shall charge the cable after permission of CNP authority in presence of CNP engineer.

### **Terms and Conditions:**

1. The interested bidders must visit CNP site prior to submitting the quote and satisfy themselves as regards to the total scope of work and give in writing along with the Bid that they have fully understood the complete scope of work and have no complaints in this regard.

2. The successful bidder will have to complete the entire work to the satisfaction of CNP, as per the given scope and quoted rates without any additional cost to CNP.

3. The site can be inspected on any working day excluding Sunday and holidays with prior intimation.

4. The interested bidder must be holding Valid electrical contractors license/Electrical supervisor license issued by the competent Authorities (State/Central) and copy of the same shall be enclosed along with the Bid.

5. The firm will have to carry out installation and commissioning of the supplied material at the site specified by CNP officials.

6. The firm on whom Purchase Order will be placed will have to submit detail drawings, and cable routes for approval of CNP authorities prior to starting the work. Since the work is to be carried out at productive section, the shut downs will be planned by CNP.

7. Since the entire work is to be completed on turnkey basis, all Civil, electrical, masonry and welding material or any services including that of lifting and shifting devices, tools and tackles etc complete with required skilled and unskilled labor for completion of this job work in all respect are to be brought and arranged by the firm.

8. CNP will provide only free water and electricity for the job work.

9. If any cable along the route is damaged during shifting and termination, then same shall be required to be put in service immediately without affecting CNP production within the same scope of work without any extra

cost to CNP.

10. The firm shall quote all technical details including terms and conditions in their quotation.

11. The cable used in panel wiring should be of Polycab/ Lapp / Havel's / CCI make.

12. The firm should attach valid authorization dealership certificate obtained from manufacturer of all Power Cables of offered make.

13. The firm shall supply any extra accessories, if required during the installation and Commissioning work of cables complete the Job work.

14. The above job work shall be guaranteed for minimum one year.

15. The firm shall depute electrical supervisor licensed holder, ITI holder workmen / supervise to carry out the above job work.

16. The firm shall attach the detailed product catalogue, Electrical standards compliance Certificates for Cables, along with the quotation.

17. The firm will have to provide Police Verification Certificate of the all firm representatives working in CNP to complete the Job work.

18. The firm shall carry out the above job work during normal working hours from 8.00 am to 5.00 pm. if approved by CNP competent authority; the firm will have to carry out the job work during extended hours/ Sundays and holidays.

19. The firm should follow all the safety norms of the CNP.

20. The firm awarded the contract will be completely liable for the safety and security of the persons working in the premises of the Currency Note Press.

21. Item of equipment or accessory not specifically mentioned in this specification but considered essential for efficient and satisfactory operation of individual equipment and system as a whole shall be included in the offer.

22. Any material or accessory which may not have been specifically mentioned but which is necessary or usual for satisfactory and trouble free operation and maintenance of the equipment shall be furnished without any extra charge.

23. All material and equipment supplied under this specification shall be new and unused.

24. The firm will have to give in writing that they will provide the after sales warranty for the 12 months from the date of acceptance of the job work completed & material supplied by CNP .

25. All the waste created during the work such as wires, cables, metal pieces, used glands, lugs, clamps and old used material replaced or removed during work, should be shifted by the firm to the location decided by CNP officer.

### **Test Report:**

The firm shall provide 03 sets of all the Test report specified in scope of work.

### **B) MINIMUM ELIGIBILITY CRITERIA**

**The following shall be the minimum eligibility criteria for selection of bidders:**

#### **1. Experience and past performance:**

The bidder should have experience of having successfully completed similar job works of supply, laying, installation, testing and commissioning of Electrical Power Cables and allied Electrical Work in during last 7 years ending March -2021.

- a) Three similar completed works each costing not less than the amount equal to Rs.12,11,700/- or
- b) Two similar completed works each costing not less than the amount equal to Rs.15,14,600/-or
- c) One similar completed work costing not less than the amount equal to Rs.24,23,400/-.

#### **2. Capacity and Capability:**

The bidder should be enlisted in either Central Public Works Department (CPWD) or Military Engineering Services (MES) or any other Government /PSU / Autonomous bodies.

Note: All experience, past performance and capacity/ capability related data should be certified by the authorized signatory of the bidder firm. The credentials regarding experience and past performance to the extent required as per eligibility criteria submitted by bidder should be verified from the parties for whom work has been done.

#### **3. Financial Standing:**

(a) Average Annual turnover of the bidder firm should be more than Rs. 12,11,700/- during last three years i.e. 2018-2019, 2019-2020 and 2020-2021.

(b) Bidder firm should not have suffered any financial loss for more than one year during the last three financial years i.e. 2018-2019, 2019-2020 and 2020-2021.

(c) The net worth of the firm should not be negative and should not have eroded by more than 30% in the last three financial years i.e. 2018-2019, 2019-2020 and 2020-2021.

3. The bidder should submit Power of Attorney of the Authorized Signatory for signing the bid, entering in to contract, if awarded and for any other correspondences.

4. The bidders shall enclose attested copy of GST Registration (in REG 06) & attested copy of PAN.

5. The bidder should give undertaking/declaration that they have read and understood all the terms & conditions of tender documents and submitting unconditional acceptance to all terms & conditions.

6. The bidder should give a declaration that they have not been black-listed/ debarred for dealing by Government of India in the past.

7. Note:-

(i) In support of experience & capability criteria, the bidder has to submit attested copies of P.O's, Experience certificates issue by customers.

(ii) All experience, past performance & capacity/ capability related/data should be certified by the authorized signatory of the bidder firm. The credentials regarding experience and past performance to the extent required as per eligibility criteria submitted by bidder may be verified from the parties for whom work has been done.

(iii) All financial standing data such as Balance Sheet, Profit & Loss account statement etc. should be certified by certified accountants e.g. Chartered Accounts or Cost Accountant. Financial statement duly certified by CA for year 2018-2019, 2019-2020 and 2020-2021 to be submitted.

**Bidder to furnish stipulated documents support of fulfillment of qualifying criteria. Non submission or incomplete submission of documents may lead to rejection of offer.**

**D) Required Delivery Schedule :** The firm will have to supply all above material & complete the job work within 90 days after issue of purchase order. Above Tender is to be executed is to be executed on turnkey basis hence only supply of material is not acceptable.

**E) Warranty :** The firm will have to give minimum one year warranty for offered entire material and workmanship after acceptance of material and job work by the purchaser. The seller shall furnish the sellers guarantee certificate for all the material/services supplied.

**F) Undertaking:**

i) Undertaking for acceptance of Buyer Added Bid Specific Terms & Conditions to be submitted duly sealed and signed.

ii) Undertaking for acceptance of Buyer Added Bid Specific Additional Technical Terms & Conditions to be submitted duly sealed and signed.

**2. Forms of EMD and PBG**

Bidders can also submit the EMD with Account Payee Demand Draft in favour of CNP, A UNIT OF SPMCIL payable at NASHIK.

Bidder has to upload scanned copy / proof of the DD along with bid and has to ensure delivery of hardcopy to the Buyer within 5 days of Bid End date / Bid Opening date.

**3. Forms of EMD and PBG**

Bidders can also submit the EMD with Payment online through RTGS / internet banking in Beneficiary name CURRENCY NOTE PRESS, A UNIT OF SPMCIL Account No. 201003551111 IFSC Code INDB0001451 Bank Name INDUSIND BANK Branch address ASHOKA MARG, NASHIK.

Bidder to indicate bid number and name of bidding entity in the transaction details field at the time of on-line transfer. Bidder has to upload scanned copy / proof of the Online Payment Transfer along with bid.

**4. Forms of EMD and PBG**

Bidders can also submit the EMD with Banker's Cheque in favour of CURRENCY NOTE PRESS, A UNIT OF SPMCIL payable at NASHIK.

Bidder has to upload scanned copy / proof of the BC along with bid and has to ensure delivery of hardcopy to the Buyer within 5 days of Bid End date / Bid Opening date.

**5. Certificates**

Bidder's offer is liable to be rejected if they don't upload any of the certificates / documents sought in the Bid document, ATC and Corrigendum if any.



## 6. Warranty

Warranty period of the supplied products shall be 1 years from the date of final acceptance of goods or after completion of installation, commissioning & testing of goods (if included in the scope of supply), at consignee location. OEM Warranty certificates must be submitted by Successful Bidder at the time of delivery of Goods. The seller should guarantee the rectification of goods in case of any break down during the guarantee period. Seller should have well established Installation, Commissioning, Training, Troubleshooting and Maintenance Service group in INDIA for attending the after sales service. Details of Service Centres near consignee destinations are to be uploaded along with the bid.

## 7. Generic

Data Sheet of the product(s) offered in the bid, are to be uploaded along with the bid documents. Buyers can match and verify the Data Sheet with the product specifications offered. In case of any unexplained mismatch of technical parameters, the bid is liable for rejection.

## 8. Generic

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity by up to 25% of the contracted quantity during the currency of the contract at the contracted rates. Bidders are bound to accept the orders accordingly.

## 9. Forms of EMD and PBG

Successful Bidder can submit the Performance Security in the form of Account Payee Demand Draft also (besides PBG which is allowed as per GeM GTC). DD should be made in favour of CURRENCY NOTE PRESS, A UNIT OF SPMCIL payable at NASHIK. After award of contract, Successful Bidder can upload scanned copy of the DD in place of PBG and has to ensure delivery of hard copy to the original DD to the Buyer within 15 days of award of contract.

## 10. Forms of EMD and PBG

Successful Bidder can submit the Performance Security in the form of Fixed Deposit Receipt also (besides PBG which is allowed as per GeM GTC). FDR should be made out or pledged in the name of CURRENCY NOTE PRESS, A UNIT OF SPMCIL A/C (Name of the Seller). The bank should certify on it that the deposit can be withdrawn only on the demand or with the sanction of the pledgee. For release of Security Deposit, the FDR will be released in favour of bidder by the Buyer after making endorsement on the back of the FDR duly signed and stamped along with covering letter. Successful Bidder has to upload scanned copy of the FDR document in place of PBG and has to ensure delivery of hard copy of Original FDR to the Buyer within 15 days of award of contract.

## 11. Forms of EMD and PBG

Successful Bidder can submit the Performance Security in the form of Payment online through RTGS / internet banking also (besides PBG which is allowed as per GeM GTC). On-line payment shall be in Beneficiary name CURRENCY NOTE PRESS, A UNIT OF SPMCIL Account No. 201003551111 IFSC Code INDB0001451 Bank Name INDUSIND BANK Branch address ASHOKA MARG, NASHIK. Successful Bidder to indicate Contract number and name of Seller entity in the transaction details field at the time of on-line transfer. Bidder has to upload scanned copy / proof of the Online Payment Transfer in place of PBG within 15 days of award of contract.

## 12. Generic

**Upload Manufacturer authorization:** Wherever Authorised Distributors are submitting the bid, Manufacturers Authorisation Form (MAF)/Certificate with OEM details such as name, designation, address, e-mail Id and Phone No. required to be furnished along with the bid.

## Disclaimer

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent

Authority in Buyer Organization. Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specification and / or terms and conditions governing the bid. Any clause incorporated by the Buyer such as demanding Tender Sample, incorporating any clause against the MSME policy and Preference to make in India Policy, mandating any Brand names or Foreign Certification, changing the default time period for Acceptance of material or payment timeline governed by OM of Department of Expenditure shall be null and void and would not be considered part of bid. Further any reference of conditions published on any external site or reference to external documents / clauses shall also be null and void. If any seller has any objection / grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

[This Bid is also governed by the General Terms and Conditions](#)

In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

**---Thank You---**