


CpsO ji

STP &amp; ETP work Clarification:-

Point No	Description	Clarification
1	Capacity of Plant	i. ETP - 20KLD ii. STP - 50KLD
2	Wages For Manpower	Central Labour Contract Act
3	Maintenance of the Plant	Comprehensive Maintenance
4	Replacement of damaged or not working equipment's	Vendors Scope Already Given details GeM tender in <b>Scope of Work</b> Point No. B, D, R and U
5	Authorization letter from Original Equipment Manufacturer(OEM)	Supplier should provide documents to provide his capabilities.
6	To obtain renewal of consent under Water (Prevention & Control of Pollution) Act 1974 and Air (Prevention & Control of Pollution) Act 1981 and Authorization of Hazardous and other waste (Management and Trans boundary movement) Rules 2016 from Telangana Pollution Control Board.	Clients Scope. However any queries or any support required for renewal of consent needs to be done by the vender.

  
DGM (TC) 18/6/2022